



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2020-21/ 9861

Dated: 01/02/2021

To
✓ The Principal
All Saints' Church Sr. Sec. School,
M.I. Road,
Jaipur (Raj)-302001

Not valid for Water
Quality Legal Case


The sample was not collected
by this laboratory.

Reference : - Your Application on Dated 27.01.2021
GRN NO. : - 46854045 Paid on Date 28.01.2021

Distt: Jaipur
Tehsil: Jaipur
Name of Sample Taker - Self

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/Unsatisfactory)
P:45 ----- 3862	28.01.2021	28.01.2021	—	M.I. Road, Jaipur	R.O. Water, All Saints' Church Sr. Sec. School, M.I. Road, Jaipur	Nil	Nil	Satisfactory

No: Lab/Bact/2020-21/
Copy to:
1. The Chief Chemist, PHED, Rajasthan, Jaipur


Superintending Chemist
PHED, Laboratory, Jaipur
Dated: 01/02/21

~~Superintending Chemist
PHED, Laboratory, Jaipur
Dated:~~

Annexure 23

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No.: Lab/Sup.Chem. (H.M.)/Jaipur (City)/2020-21/ 10370

Date: 10/02/2021


To,
 ✓ The Principal
 All Saints' Church Sr. Sec. School,
 M.I. Road, Jaipur

Not valid for Water
 Quality Legal Case

The sample was not collected
 by this laboratory.

Date of Receipt: 28.01.2021

Source	Permissible Value as per B.I.S : 10500/2012		RO Water
Location			School Campus, All Saints' Church Sr. Sec. School M.I. Road, Jaipur
Village/Town			Jaipur
Date of Collection			28.01.2021
Sample No.	Requirement (Acceptable Limit)	Permissible limit in absence of alternate Source	P-57
1. pH	6.5 to 8.5	No relaxation	7.40
2. Turbidity(NTU)	1	5	Nil
3. Colour (Hazen Units)	5	15	None
4. Odour	Un Objectionable	Un Objectionable	Un Objectionable
5. Total Alkalinity (as CaCO ₃) mg/L	200	600	50
6. Total Hardness (as CaCO ₃) mg/L	200	600	40
7. Calcium (as Ca) mg/L	75	200	5
8. Magnesium (as Mg) mg/L	30	100	7
9. Chloride(as Cl) mg/L	250	1000	30
10. Nitrate as(NO ₃) mg/L	45	45	20
11. Sulphate(as SO ₄) mg/L	200	400	8
12. Total Dissolved Solids mg/L	500	2000	196
13. Fluoride mg/L	1.0	1.5	0.09
14. Iron mg/L	1.0	No Relaxation	Nil
15. Arsenic mg/L	0.01	No Relaxation	Nil


 Superintending Chemist (Heavy Metals)


P.H.E.D. Laboratory, Jaipur

Date:

No.: Lab/Sup.Chem. (H.M.)/Jaipur (City)/2020-21

Copy To:-

1. Chief Chemist, P.H.E.D. Raj., Jaipur


 Superintending Chemist (Heavy Metals)

P.H.E.D. Laboratory, Jaipur

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 384

Date : 14.07.2021

It is certified that an inspection team headed by Deepak singhal, Assistant Engineer, PHED and Panchuram swami, Junior Engineer (Name of Officers with designation) from Public Health Engineering Department, Gopalwadi (Name of Department/Office) inspected the ALL SAINTS' CHURCH SR. SEC. SCHOOL, M.I. ROAD, JAIPUR (Name & Address of the School) on 14.07.2021 and found that the ALL SAINTS' CHURCH SR. SEC. SCHOOL, M.I. ROAD, JAIPUR (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Signature with Seal : _____

Name

Designation

14/07/2021
सि.सं. 14/07/2021
जन.स्वा.आरं. विभाग
नगर उपकरण चतुर्थ (द.)
जयपुर

: Deepak singhal

: Assistant Engineer, PHED
Gopalwadi, Jaipur.

To

ALL SAINTS' CHURCH SR. SEC. SCHOOL

M.I. ROAD,

JAIPUR 302001

(Name & Address of the Institution)